

GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



SEE RULE - 18(2)

F O R M - (G)

No. F&ES/FPW/ 219(22-2)/191/19

Dated Guwahati the 28/6/19

To,

The Principal,
Dhemaji P.G.T. College,
Ward No. 07, (Nimati Chuk Village),
Dist:- Dhemaji, Assam.

NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND FIRE SAFETY MEASURES IN THE DHEMAJI P.G.T. COLLEGE AT WARD NO. 07, (NIMATI CHUK VILLAGE), DIST:- DHEMAJI, ASSAM.

With reference to your compliance report under No. NIL

Dated **21.05.2019** I hereby certified that the building as per description below at
Dag No. **369, 370** Patta No. **NIL** Mouza **Dhemaji,**
(Place **Ward No. 07, Dhemaji**) has been inspected in respect of implementation of Inbuilt Fire Fighting, Fire Prevention and Fire Safety measures and is declared fit in respect fire safety. The Fire & Emergency Services, Assam has no objection in its occupation /utilization for the purpose of **COLLEGE** subject to condition mentioned over leaf.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR:-

1. Floor area: - **4632 ft^2 (Assam Type)**
1336 ft^2 (RCC)
2. Purpose of utilization: -
For College Purpose.

MEZZANINE/ BASEMENT FLOOR:-

1. Floor area: -
2. Purpose of utilization: -

FIRST FLOOR:-

1. Floor area: -
2. Purpose of utilization: -

SECOND FLOOR:-

1. Floor area: -
2. Purpose of utilization: -

THIRD FLOOR:-

1. Floor area: -
2. Purpose of utilization: -

FOURTH FLOOR:-

1. Floor area: -
2. Purpose of utilization: -

FIFTH FLOOR:-

1. Floor area: -
2. Purpose of utilization: -

SIXTH FLOOR:-

1. Floor area: -
2. Purpose of utilization: -

Contd... P/2

SEVENTH FLOOR:-

1. Floor area: -

2. Purpose of utilization: -

EIGHT FLOOR:-

1. Floor area:-

2. Purpose of utilization:-

NINTH FLOOR:-

1. Floor area: -

2. Purpose of utilization: -

TENTH FLOOR:-

1. Floor area:-

2. Purpose of utilization:-

S.P. Cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

NO. F&ES/FPW/

Dated Guwahati the

Copy to:-

1. The Deputy Commissioner, **Dhemaji**, Assam for information and necessary action.
2. The Commissioner/ Chairman, **Dhemaji Municipal Board**, Assam for information and necessary action.
3. The Response Team Commander, **Dhemaji F&ES Station** for information.

S.P. Cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITION:-

1. The N.O.C. is valid up to: - **31.03.2020**.
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.

S.P. Cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

**OFFICE OF THE FIRE & EMERGENCY SERVICES
STATION::DHEMAJI, ASSAM**

NO.DMJ/F&ESS/65/244/19

Dated : 22.05.19



To,

The Principal
P.G.T. College, Dhemaji
Ward No. 07 (Nimati Chuk Village)
Dhemaji.

Sub: Implementation of Fire Prevention and Means of Escape Measures in existing Assam type and RCC G+1 building of P.G.T. College, bearing Dag No. 369, 370, Patta No., Mouza:- Dhemaji, Dist:- Dhemaji, Assam.

Ref. Your letter No. DMJ/PGTC/RTC/DFES/113 date: 21.05.19

Sir,

With reference to the subject cited above, I have visited and inspected your college building on 21.05.19 and suggested and you are requested to implement the following Fire preventive and means of escape measures in the existing **Building of your college** at the above noted location for safety of lives and properties as well as the building itself.

RECOMMENDATION AND SUGGESTION OF THE PREVENTIVE AND MEANS OF ESCAPE MEASURES (as per National Building code of India Part IV- 2016)

Electrical services:

1. The building shall be provided with the lighting arrestors.
2. Electrical wiring shall be either conceal or conduit type.

Fire fighting:

1. 2(two) no. Fire Point consisting 3(three) nos. of water bucket or sand bucket each, one no. fire beater and one no. Ceiling hook shall be provided in front of office or easily accessible place.
2. 1(one) nos. CO₂ and 3(three) nos. of ABC Extinguisher of 4.5 and 10 kg capacity respectively with ISI mark should be installed at every floor of entire building at a distance of 15 mtr. each extinguisher.
3. 2(two) nos. CO₂ Extinguisher 4.5 kg and 1(one) no. ABC extinguisher 4 kg with ISI mark should be provided near the electric panel board.
4. 2(two) nos. of CO₂ extinguisher 4.5 Kg should be provided (wall hanging) covering all computer rooms, library room and at laboratory room.
5. 2(two) nos. of ABC extinguisher 4 kg should be installed inside store room.
6. Remove all inflammable materials from the campus.

N.B.: All Fire Extinguishers should be newly introduced with Indian Standard – as per IS 15683:2006

Cont...2

Fire alarm system:


1. The building shall be equipped with manually operated electrical fire alarm system (MOEFA) covering every floor and rooms.

General precaution:

1. The staff of the college shall be trained to operate the portable fire extinguisher in case of emergency.
2. For total evacuation the building should have emergency exit with dark red arrow symbol and written as EMERGENCY EXIT indicating to the open space or place of safety.
3. Good housekeeping shall be maintained.
4. Emergency Telephone Numbers shall be displayed in conspicuous place.
(Telephone no. of Dhemaji Fire & Emergency Services Station-9707901947 or 101)
5. "NO SMOKING" sign boards shall be displayed.

PLEASE DO NOT TREAT THIS AS N.O.C., FORMAL N.O.C. WILL BE ISSUED ONLY AFTER IMPLEMENTATION OF THE FIRE PREVENTIVE MEASURES AS PER SUGGESTION AND ON RECEIPT OF PARAWISE COMPLIANCE REPORT FROM YOUR END AND AFTER SATISFACTORY INSPECTION REPORT OF TECHNICAL OFFICERS OF THIS DEPARTMENT.

Yours faithfully



Response team Commander
Fire & Emergency services Station
Dhemaji, Assam
DT. 22.05.19

NO.DM/J/F&ESS/65/ /19

Copy to:

1. The Spl.DGP cum Director of Fire & Emergency Services Assam Ghy. for kind information and necessary action.
2. The Deputy Commissioner, Dhemaji, Assam for favour of information and necessary action.

Response team Commander
Fire & Emergency services Station
Dhemaji, Assam

File No. 07410035/4028

Dated Guwahati the 8/03/2017.....

This registration however does not make the Registrar liable for any default / liability on loan from Banks, Private Societies, Govt. and Semi-Govt. Sources of payment of I.T. and Sales Tax, as the case may be created by the society.

Financial Institutions, Govt. and Semi-Govt. Depts. extending financial Grants - in- aids etc. to the Society shall send copies of such sanctions to the Registrar for his record.



सत्यमेव जयते



CERTIFICATE OF REGISTRATION OF SOCIETIES ACT XXI OF 1860

No. RS/ DMJ / 241 / B / 01 of 2012 - 2013

I hereby Certify that GOVERNING BODY DHEMAJI POST GRADUATE
TRAINING COLLEGE

Dhemaji P.G.T. College Campus, Vill.-Nimati Chuk Gaon, P.O.-Gohain Gaon,

P.S. & Dist.-Dhemaji, Assam, Pin.-787057

has this day been registered under the Societies Registration Act. XXI of 1860.

Given under my hand at Guwahati

this 11th *day of* April

Two thousand twelve.

VALID UP-TO 10-04-2015

VALIDITY EXTENDED UP-TO 02-03-2020

(Signature)
Registrar of Firms and
Societies, Assam
Guwahati-8/3/17

(SD/-A. DEB LASKAR)
REGISTRAR OF SOCIETIES, ASSAM
GUWAHATI

N.B.-Registered number of Societies should not be stated as Government registered. It is registered under S.R.Act.XXI of 1860.

"Please read carefully the rules written overleaf"